

CERTIFICATION OF ELEVATION

029A-013

DATE: JULY 6, 1987

ADDRESS OF PROPERTY LOT 13

BAILEY'S MILL

CAMDEN COUNTY, GEORGIA

FLOOD ZONE A V OTHER _____

Required lowest finished floor elevation 14.0 MSL
(If V Zone, required elevation of the bottom of
the lowest horizontal structural member)

Actual lowest floor elevation 15.96 MSL

The undersigned hereby certifies to the above information.



PARK D. PRIVETT, JR.
PRIVETT & ASSOCIATES, INC.

STATE OF GEORGIA

REGISTRATION NO. 2218