

033C-003

CERTIFICATION OF ELEVATION

DATE: October 9, 1987

ADDRESS OF PROPERTY Lot 3, Springhill -
Unit 1, Camden County,
Georgia

FLOOD ZONE A V OTHER _____

Required lowest finished floor elevation 11.00 MSL
(If V Zone, required elevation of the bottom of
the lowest horizontal structural member)

Average Lot
~~XXXXXXXX~~ ~~XXXXXXXX~~ ~~XXXXXX~~ elevation 11.60 MSL

The undersigned hereby certifies to the above information.

Park D. Privett, Jr.
Privett & Associates, Inc.

STATE OF Georgia

REGISTRATION NO. 2218

033C-003

CERTIFICATION OF ELEVATION

DATE: January 26, 1988

ADDRESS OF PROPERTY Lot 3, Springhill - Unit
One, Camden County, Georgia

FLOOD ZONE A V OTHER _____

Required lowest finished floor elevation 11.00 MSL
(If V Zone, required elevation of the bottom of
the lowest horizontal structural member)

Actual lowest floor elevation 13.04 MSL

The undersigned hereby certifies to the above information.



Park D. Privett, Jr.

Privett & Associates, Inc.

STATE OF Georgia

REGISTRATION NO. 2218

