

074A-013

CERTIFICATION OF ELEVATION

DATE: March 25, 1987

ADDRESS OF PROPERTY Lot 13, Red Bluff

Subdivision

Camden County, Georgia

FLOOD ZONE A V OTHER _____

Required lowest finished floor elevation 14.00 MSL
(If V Zone, required elevation of the bottom of
the lowest horizontal structural member)

Actual lowest floor elevation 15.22 MSL

The undersigned hereby certifies to the above information.



Park D. Privett, Jr.
Privett & Associates, Inc.

STATE OF Georgia

REGISTRATION NO. 2218