

CERTIFICATION OF ELEVATION

108C-012

DATE: November 15, 1988


ADDRESS OF PROPERTY Lot 12 Deer Run
Camden County, Georgia

FLOOD ZONE A V OTHER "X" (SHADED)

Required lowest finished floor elevation 13.5 MSL
(If V Zone, required elevation of the bottom of
the lowest horizontal structural member)

Actual lowest floor elevation 13.62 MSL

The undersigned hereby certifies to the above information.



Park D. Privett, Jr.

PRIVETT & ASSOCIATES, INC.

STATE OF Georgia

REGISTRATION NO. 2218

F.B. 103 pg. 73

Reference survey by this firm dated November 15, 1988
Drawing No. B-1-864(A)-3-88.