

160A-097

CERTIFICATION OF ELEVATION

DATE: March 13, 1987

ADDRESS OF PROPERTY Lot 22, Block "A"

River Oaks at Point Peter

FLOOD ZONE A V OTHER _____

Required lowest finished floor elevation 12.00 MSL
(If V Zone, required elevation of the bottom of
the lowest horizontal structural member)

Actual lowest floor elevation 12.31 MSL

The undersigned hereby certifies to the above information.

Park Dean Privett, Jr.
Privett and Associates, Inc.

STATE OF Georgia

REGISTRATION NO. 2218